

2016-01-04

Fritz,

Thanks for the heads up. I will come up with some notes for you. Since it will no longer be a single driveway, I think that I will be requesting that the main drive from Rte 9 be brought up to the Fire Lane requirements as layer out in the State Fire Code. Also, since this driveway is longer than what we carry for supply hose on any single unit, some form of fire protection should be in place, be it a cistern or having the new dwellings protected by 13D Sprinkler systems.

Respectfully,

Tom Perley  
Fire Chief/EMD  
Town of Madbury  
334 Knoxmarsh Road  
Madbury, New Hampshire 03823  
Office - [\(603\) 742-1164](tel:6037421164)  
Cell - [\(603\) 617-0562](tel:6036170562)