



JUN 30 2016

6-30-16 TO PLANNING BOARD
COPY TO BUILDING INSP.

ROCKINGHAM COUNTY CONSERVATION DISTRICT

110 North Road, Brentwood, NH 03833-6614
Tel: 603-679-2790 • Fax: 603-679-2860
www.rockinghamccd.org

22 June 2016

Eric Fiegenbaum, Administrative Assistant
Town of Madbury
13 Town Hall Road
Madbury, NH 03820

RE: Smith
281 Littleworth Road
Tax map/lot: 1/22
RCCD #MA1-22-L16

Dear Mr. Fiegenbaum;

On this date I witnessed one additional test pit for a proposed residential subdivision. The designer representing the owner was Marc Jacobs.

The following features were observed:

Test Pit	Seasonal High Water Table	Bedrock	Total Depth	Pass/Fail
5	24"	none	76"	pass

Test pit five meets town and state soil requirements for wastewater disposal.

A test pit field summary is attached.

Sincerely,

Michael Cuomo
NH Certified Soil Scientist #6
NH Certified Wetland Scientist #4
NH Designer #788

Leonard A. Lord
District Manager

LITTLEWORTH

PROJECT: WADSBURY 281 LITTLEWORTH RD

SMITH

RCCD 002
1-22

DATE: 2/25/16 EVALUATOR: UNAC JACOBS

CO: _____

WITNESSED BY: MICHAEL CUOMO

TITLE: NH CERTIFIED SOIL SCIENTIST #6

TEST PIT # <u>5</u> OF <u>1</u>	LOT #	LOCATION	E.S.H.W.T. @ <u>24"</u>	W.S.P.C.C. GROUP <u>3</u>
TERMINATED @ <u>76"</u>	REFUSAL ? Y / N <u>(N)</u>	OBSERVED H ₂ O @ <u>0"</u>	ROOTS TO: <u>few"</u>	SCS/HIS SOIL TYPE: <u>343BP</u> <u>EMW000</u>
DEDICATED LEACH AREA <u>(Y)</u> / N	DISTANCE TO HYDRIC B	DISTANCE TO HYDRIC A	DEPTH TO IMPERMEABLE <u>SILT LOAM</u> <u>30"</u>	SUBDIVISION SEPTIC <u>X</u>

COMMENTS: PASS

TEST PIT # OF	LOT #	LOCATION	E.S.H.W.T. @ "	W.S.P.C.C. GROUP
TERMINATED @ "	REFUSAL ? Y / N	OBSERVED H ₂ O @ "	ROOTS TO: "	SCS/HIS SOIL TYPE: _____
DEDICATED LEACH AREA Y / N	DISTANCE TO HYDRIC B	DISTANCE TO HYDRIC A	DEPTH TO IMPERMEABLE	SUBDIVISION SEPTIC _____

COMMENTS:

TEST PIT # OF	LOT #	LOCATION	E.S.H.W.T. @ "	W.S.P.C.C. GROUP
TERMINATED @ "	REFUSAL ? Y / N	OBSERVED H ₂ O @ "	ROOTS TO: "	SCS/HIS SOIL TYPE: _____
DEDICATED LEACH AREA Y / N	DISTANCE TO HYDRIC B	DISTANCE TO HYDRIC A	DEPTH TO IMPERMEABLE	SUBDIVISION SEPTIC _____

COMMENTS: