

FEB 17 2017

70 PB 2-20-2017



ROCKINGHAM COUNTY CONSERVATION DISTRICT

110 North Road, Brentwood, NH 03833-6614
Tel: 603-679-2790 • Fax: 603-679-2860
www.rockinghamccd.org

8 February 2017

Eric Fiegenbaum, Administrative Assistant
Town of Madbury
13 Town Hall Road
Madbury, NH 03820

RE: Jakobs
55 Evans Road
Tax map/lot: 8/6
RCCD # MA8-6-L17

Dear Mr. Fiegenbaum;

On this date RCCD witnessed two test pits for a lot line adjustment. The designer representing the owner was Adam Fogg.

The following features were observed:

Test Pit	Seasonal High Water Table	Bedrock	Total Depth	Pass/Fail
1	32"	no	76"	pass
2	48"	no	62"	pass

Test pits 1 and 2 meet Town and State soil and wetland setback requirements for a wastewater disposal system.

A test pit field summary is attached.

Sincerely,

Michael Cuomo
NH Certified Soil Scientist #6
NH Certified Wetland Scientist #4
NH Designer #788

Leonard A. Lord
District Manager

PROJECT: MADISON STEPHENS RD JACOBS B-6
 DATE: 3/27/17 EVALUATOR: ADAM FOGG CO: ATLANTIC SURVEY
 WITNESSED BY: MICHAEL CUMMINGS TITLE: NH CERTIFIED SOIL SCIENTIST #6

TEST PIT # <u>1</u> OF <u>2</u>	LOT #	LOCATION	E.S.H.W.T. @ <u>32</u> "	W.S.P.C.C. GROUP <u>3</u>
TERMINATED @ <u>70</u> "	REFUSAL ? Y / N <u>(N)</u>	OBSERVED H ₂ O @ <u>No</u> "	ROOTS TO: "	SCS/HIS SOIL TYPE: <u>2438B</u> <u>ECR-R-DE</u>
DEDICATED LEACH AREA Y / N <u>(Y)</u>	DISTANCE TO HYDRIC B	DISTANCE TO HYDRIC A	DEPTH TO IMPERMEABLE <u>FROM SL 32"</u>	SUBDIVISION SEPTIC <u>X</u> <u>LOW LEACH</u>

COMMENTS: PASS

TEST PIT # <u>2</u> OF <u>2</u>	LOT #	LOCATION	E.S.H.W.T. @ <u>43</u> "	W.S.P.C.C. GROUP <u>3</u>
TERMINATED @ <u>62</u> "	REFUSAL ? Y / N <u>(N)</u>	OBSERVED H ₂ O @ <u>No</u> "	ROOTS TO: "	SCS/HIS SOIL TYPE: <u>2218B</u> <u>Horiz</u>
DEDICATED LEACH AREA Y / N <u>(Y)</u>	DISTANCE TO HYDRIC B	DISTANCE TO HYDRIC A	DEPTH TO IMPERMEABLE <u>No</u>	SUBDIVISION SEPTIC <u>X</u>

COMMENTS: PASS

TEST PIT # OF	LOT #	LOCATION	E.S.H.W.T. @ "	W.S.P.C.C. GROUP
TERMINATED @ "	REFUSAL ? Y / N	OBSERVED H ₂ O @ "	ROOTS TO: "	SCS/HIS SOIL TYPE:
DEDICATED LEACH AREA Y / N	DISTANCE TO HYDRIC B	DISTANCE TO HYDRIC A	DEPTH TO IMPERMEABLE	SUBDIVISION SEPTIC

COMMENTS: