


Town of Madbury
13 Town Hall Road
Madbury, NH 03823




Attn: Planning Board

Re: SOIL PROBES at the Property of William Janelle
6 Jenkins Road - Tax Map 11, Lot 14C

On April 28, 2017, I conducted soil probes to test the soil suitability for potential replacement areas for the existing septic leach field. I probed two areas, with shovel and auger, to a depth of 3 ½ feet. These areas consist of moderately well drained fine sandy soils with water tables greater than 24" and are suitable for a leach field.

This finding is consistent with a high intensity soil map of the subject parcel, dated 5/25/88 by James Long, NH Certified Soil Scientist and Designer. This map shows this area as soil type 311BH, which indicates a moderately well drained glacial outwash with no restrictive layers and <8% slopes.

Sincerely,



Kenneth J. Faucher
NH Designer #851

