

## ROCKINGHAM COUNTY CONSERVATION DISTRICT

110 North Road, Brentwood, NH 03833-6614 Tel: 603-679-2790 • Fax: 603-679-2860 www.rockinghamced.org

16 July 2015

Eric Fiegenbaum, Administrative Assistant Town of Madbury 13 Town Hall Road Madbury, NH 03820

RE:

Maple Heights Realty

Hayes Road Tax map/lot: 5/8 RCCD #MA5-8-L15

Dear Mr. Fiegenbaum;

On this date I witnessed 2 additional test pits for a proposed residential subdivision. The designer representing the owner was Wayne Morrill of Jones and Beach Engineers.

The following features were observed:

Test Pit	Seasonal High Water Table	Bedrock	Total Depth	Pass/Fail
M13	36"	no	63"	pass
M14	28"	no	64"	pass

Both of today's test pits meet town and state soil requirements for wastewater disposal. Whether the test pits meet setback requirements and the acceptability of the 4,000 square foot reserve area can be determined after the test pits are survey located and presented on the subdivision plan.

A test pit field summary is attached.

Sincerely,

Michael Cuomo

NH Certified Soil Scientist #6

Whatal am

NH Certified Wetland Scientist #4

NH Designer #788

Loonard A. Lord District Manager