



Edited on 1/18/17 to show test results when current Town & State requirements are applied. -Kurt Schreiber

Schreiber
42 Cherry Lane
Tax map/lot: 6/13
RCCD #MA6-13-L13

Note: Town & State now share 48" Minimum distance to bedrock.

"Pass" = 24" or greater.

Test Pit	Seasonal High Water Table	Bedrock	Total Depth	Pass/Fail
1 Lot "B"	26" P	yes	30-48" P	pass
2 Lot "B"	30" P	yes	38-54" P	pass
3 Lot "B"	20" F	yes	36" fail	fail
4 Lot "A"	32" P	yes	60" P	pass
5 Lot "A"	24" P	yes	62" P	pass
6 Lot "A"	21" F	no	60" P	fail
7 Lot "A"	13" F	no	55" P	fail
8 Lot "B"	26" P	yes	48" P	pass

& 1, 2, 8

Test pits 4 and 5 meet town and state soil requirements for wastewater disposal.

Test pits 3, 6, and 7 do not meet local soil requirements because the water table is less than 24 inches from the surface.

Tests pits 3, 6, and 7 do not meet local soil requirements because bedrock is less than 48 inches from the surface.

The wetlands were not yet identified at the time this work was done.