

Test Pit	Seasonal High Water Table	Bedrock	Total Depth	Zoning Ordinance	Subdivision Regulations	Site Plan Review	Building Regulations
B 1	26	Yes	30 - 48	pass	pass	pass	fail
B 2	30	Yes	38 - 54	pass	pass	pass	fail
B 3	20	Yes	36	fail	fail	fail	fail
A 4	32	Yes	60	pass	pass	pass	pass
A 5	24	Yes	62	pass	pass	pass	pass
A 6	21	No	60	fail	fail	fail	fail
A 7	13	No	55	fail	fail	fail	fail
B 8	26	Yes	48	pass	pass	pass	pass

All Measurements in Inches

red unconditional fail
green unconditional pass
blue conditional pass (if building regulations reduced from 60 to 48)

FWG 2014-02-12