

**TEST PITS
FOR
81 OLD STAGE ROAD
MADBURY, NH
FEBURARY 12, 2025
JBE Project No. 25011**

Performed by: Anthony Jones, Jones & Beach Engineers, Inc., SSD #1900
Witnessed by: Michael Cuomo, Rockingham County Conservation District

Test Pit #1

| | | |
|-----------|----------|---|
| 0" - 12" | 10YR 3/3 | dark brown fine sandy loam granular, friable |
| 12" - 28" | 10YR 3/3 | dark brown fine sandy loam granular, friable common roots |
| 28" - 36" | 10YR 5/6 | yellowish brown loamy sand granular, friable common roots |
| 36" - 72" | 2.5Y 5/4 | light olive brown loamy sand blocky, friable common distinct redox |

SHWT = 36"
Roots: 36"
No H₂O observed
Refusal observed at 72"
Perc Rate = 8 min/inch



Test Pit #2 (Does not meet town standards)

| | | |
|-----------|----------|--|
| 0" - 6" | 10YR 3/3 | dark brown fine sandy loam granular, friable common roots |
| 6" - 13" | 10YR 5/6 | yellowish brown loamy sand massive, friable common roots |
| 13" - 24" | 2.5Y 6/2 | light brownish gray silty clay loam angular blocky, very firm many distinct redox |

SHWT = 13"
Roots to 24"
No H₂O observed
No Refusal observed

